



CB TEST CERTIFICATE

Ref. Certificate No.

NL-12067

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Circuit-breaker for overcurrent protection		
Applicant:	LS INDUSTRIAL SYSTEMS CO., LTD.	Cheong Ju plant, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720	Korea, Republic of
Manufacturer:	SHANGHAI YONGJI ELECTRICAL HOLDING CO., LTD	2239, QianYuJinShi Road, JinShan WeiTown, Shanghai	China
Factory:	SHANGHAI YONGJI ELECTRICAL HOLDING CO., LTD	2239, QianYuJinShi Road, JinShan WeiTown, Shanghai	China
Rating and principal characteristics:	2P, 3P, 3P+N 415 Vac, 1P 240/415 Vac 1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A B, C, D type Icn 10 kA		
Trade mark (if any):	LS		
Model/Type reference:	BKM-b		
Additional information:	Energy limiting class 3 (acc. to EN 60898-1:2003+A1:2004		
Sample of product tested to be in conformity with IEC:	60898-1(ed.1);am1;am2		
Test Report Ref. No:	S0703110.50		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2007-03-29